



Remmers GmbH
Report No. RE 1808-1062

Cleanroom[®] Suitable Materials

Epoxy OS Color
Particle (vs. PA6): ISO 3

FLOORING & COATING

Particle Emission

Qualification Certificate

We hereby certify that the material stated above, provided by

Remmers GmbH
Löningen, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RE 1808-1062.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Epoxy OS Color (color: light gray)	vs. PA6	ISO Class: 3
Reel-on-disc test Normal force 300N		

DUPLICATE

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

RE 1808-1062
Report No. first document
--
Report No. current document

Stuttgart, October 29, 2018
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA